



Note: Maximum total output must not exceed 6 amps.

For larger capacity Primary Pumps etc output should be "slaved" via a suitable 230V/50Hz relay.

\* connect only single speed 230VAC/50Hz fans directly to L5

\*\* fans utilising 0-10volt output for speed control must be connected to L5 for 230V/50Hz supply with control provided via A1 & 0V plus select 0-10volt control in software

## FARM2000

M&K PRODUCTS (BROMSGROVE) LTD  
Dodford, Bromsgrove, Worcs, B61 9BT  
Tel: 01527 821621 Fax: 01527 821665

The original of this drawing is the exclusive property of M&K Products Ltd. and the acceptance of this print constitutes an agreement that it will be treated as a confidential document to be used for no other purpose other than aid in the assembly or operation of M&K Product's equipment or as otherwise expressly authorised by M&K Products Ltd. These drawings are not to be communicated, disclosed, copied or published except as expressly authorised in writing by M&K Products Ltd.

No.	DATE	ALTERATION

TITLE  
TS2 - ELECTRICAL  
CONNECTION DIAGRAM

DRAWN	DATE	MATL.	SCALE
TLW	11/16		n.t.s

USED ON  
HT36, HT46R, HT50R, HT60R,  
HT70R, HT80R, BB144/3R, BB146/3R  
& BB154/3R

DRG. No.

# TS2